



Certificate of Compliance

Certificate: 70181802

Master Contract: 272557

Project: 70181802

Date Issued: August 16, 2018

Issued to: Techno Controls
Plot No. 54/1, survey No. 299
Ahmedabad, Gujarat, 382481
INDIA
Attention: Daxesh Shah

The products listed below are eligible to bear the CSA Mark shown



Issued by: Adam Traverse
Adam Traverse

PRODUCTS

CLASS 2258 04 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe, Entity - For Hazardous Locations

CLASS 2258 84 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe, Entity - - For Hazardous Locations - Certified to US Standards

Class I, Division 1, Groups A, B, C and D

Ex ia IIC Ga

Class I, Zone 0, AEx ia IIC Ga

-50°C < T_{amb} < 180°C

Ui = 12V, Ii = 35mA, Pi = 105mW

TSR* and TBTD-* series

The TSR* and TBTD-* series resistance temperature devices (RTDs) are typically used to measure internal temperatures of motors/generators. The TSR* series RTDs are slot resistance thermometers, whereas the TBTD-* series RTDs are bearing temperature detectors. Both series are available with 2, 3 or 4 wire options and are connected by means of flying leads to a suitably certified intrinsically safe barrier supply.

Notes:

1. The above model is fixed connection, Pollution Degree 2, Overvoltage Category I.
2. Environmental Conditions: Extended, Outdoor use, -50°C to +180°C.



Certificate: 70181802
Project: 70181802

Master Contract: 272557
Date Issued: August 16, 2018

Conditions of Acceptability:

1. For Zone 0 'ia'/Division 1 applications, equipment must be fed by a suitably certified intrinsically safe barrier supply, of the following entity parameters:

Ui	Ii	Pi	Ci	Li
12V	35mA	105mW	*	*

*cable inductance and capacitance only.

2. The maximum operating temperature of the equipment is $-50^{\circ}\text{C} < T_{\text{amb}} < 180^{\circ}\text{C}$. External sources of heating due to the intended equipment application are to be taken into consideration during installation in order to ensure the maximum ambient temperature of equipment is not exceeded. This condition is subjected to acceptance of local authorities having jurisdiction.
3. End-user shall ensure proper earthing of the equipment upon installation in accordance with applicable CEC and NEC codes. The mounting of the equipment into installation must ensure that the metallic body is reliably connected to system earth, continuity to be checked and confirmed.
4. TSR-* series only: where the insulated wiring has no overall sheath, the conductor insulation has a minimum thickness of only 0.09 mm (code Z) or 0.12 mm (codes Q, R, W, X, Y), so precautions shall be taken to prevent contact with other current-carrying conductors, for example by the use of additional insulation or routing away from other conductors.

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

CLASS 2258 82 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations - Certified to US Standards

Class I, Division 2, Groups A, B, C and D

Ex eb IIC Gb

Class I, Zone 1, AEx eb IIC Gb

$-50^{\circ}\text{C} < T_{\text{amb}} < 180^{\circ}\text{C}$

Electrical Rating: V = 10V, I = 10mA, P = 1.5W

TSR* series

The TSR* series resistance temperature devices (RTDs) are typically used to measure internal temperatures of motors/generators. The TSR* series RTDs are slot resistance thermometers. Available with 2, 3 or 4 wire options and are connected by means of flying leads to a Class 2 low power supply.

Notes:

1. The above model is fixed connection, Pollution Degree 2, Installation Category I.
2. Environmental Conditions: Extended, outdoor use. (For Zone 1 'eb' applications: within a certified Ex e enclosure minimum IP54 rating, with flying leads terminated by means of Ex e terminals, or a suitable protection method as detailed in CSA/UL60079-0. For Division 2 installations, the equipment shall be housed in an enclosure acceptable to the local authorities having jurisdiction. -50°C to $+180^{\circ}\text{C}$.)

Conditions of Acceptability:

1. The equipment is to be connected to a Class 2 or limited energy power source according to CSA 61010-1-12 and ISA 61010-1 3rd Edition with a maximum voltage of 30Vrms, 42.4V peak, or 60V dc. (Equipment electrical rating is: 10V, 10mA, 1.5W.)



Certificate: 70181802
Project: 70181802

Master Contract: 272557
Date Issued: August 16, 2018

2. For Division 2 installations, the equipment shall be housed in an enclosure acceptable to the local authorities having jurisdiction.
3. For Zone 1 'eb' installation, the equipment shall be housed in a certified Ex e enclosure minimum IP54 with field wiring terminated by means of Ex e terminals, or a suitable protection method as detailed in CSA/UL60079-0.
4. For Zone 1 'eb'/Division 2 applications the wiring method and termination shall meet the requirements of CEC (for Canada) and NEC (for USA) for Zone 1/Division 2 applications and is subjected to acceptance of local authorities having jurisdiction.
5. End-user shall ensure proper earthing of the equipment upon installation in accordance with applicable CEC and NEC codes. The mounting of the equipment into installation must ensure that the metallic body is reliably connected to system earth, continuity to be checked and confirmed.
6. The maximum operating temperature of the equipment is $-50^{\circ}\text{C} < T_{\text{amb}} < 180^{\circ}\text{C}$. External sources of heating due to the intended equipment application are to be taken into consideration during installation in order to ensure the maximum ambient temperature of equipment is not exceeded. This condition is subjected to acceptance of local authorities having jurisdiction.
7. For Zone 1 'eb' High voltage test to be performed upon final installation within motor assembly.
8. Sensors are only to be connected to measuring equipment suitable for PT100/PT1000 sensors.

APPLICABLE REQUIREMENTS

ANSI/ISA-61010-1 3 rd Edition	Safety Requirements for Electrical Equipment for Measurement, Control and Laboratory Use - Part 1: General Requirements - Third Edition
CAN/CSA C22.2 No. 61010-1-12	Safety Requirements for Electrical Equipment for Measurement, Control and Laboratory Use - Part 1: General Requirements - Third Edition
CAN/CSA-C22.2 No. 0-10 (R2015)	General Requirements – Canadian Electrical Code, Part II
CSA Std. C22.2 No. 213-2017	Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations
ANSI/ISA-12.12.01-2017	Non-Incendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations
CAN/CSA-C22.2 No. 60079-0:15	Explosive Atmospheres - Part 0: Equipment - General requirements
CAN/CSA-C22.2 No. 60079-11:14	Explosive Atmospheres – Part 11: Equipment protection by intrinsic safety "i"
CAN/CSA-C22.2 No. 60079-7:16	Explosive atmospheres - Part 7: Equipment protection by increased safety "e"
ANSI/UL 60079-0:13	Electrical Apparatus for Explosive Gas Atmospheres - Part 0: General Requirements
ANSI/UL 60079-11:13	Electrical apparatus for Explosive Gas Atmospheres - Part 11: Intrinsic Safety "i"
ANSI/UL 60079-7:16	Explosive Atmospheres - Part 7: Equipment Protection by Increased Safety "e"
UL 913, 8th Edition, R2015	Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, and III, Division 1, Hazardous (Classified) Locations



Certificate: 70181802

Project: 70181802

Master Contract: 272557

Date Issued: August 16, 2018

MARKINGS

The manufacturer is required to apply the following markings:

- Products shall be marked with the markings specified by the particular product standard.
- Products certified for Canada shall have all Caution and Warning markings in both English and French.

Additional bilingual markings not covered by the product standard(s) may be required by the Authorities Having Jurisdiction. It is the responsibility of the manufacturer to provide and apply these additional markings, where applicable, in accordance with the requirements of those authorities.

The products listed are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US (indicating that products have been manufactured to the requirements of both Canadian and U.S. Standards) or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Supplement to Certificate of Compliance

Certificate: 70181802

Master Contract: 272557

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70181802	2018-08-16	CSA c-us Certification for TSR* and TBTD-* series resistance temperature devices (RTDs): Class I, Div. 1 Groups A, B, C, D; Ex ia IIC Ga; Class I, Zone 0, AEx ia IIC Ga Class I, Div. 2 Groups A, B, C, D; Ex eb IIC Gb; Class I, Zone 1, AEx eb IIC Gb